

Pressure Vessel Engineering, Ltd.
120 Randall Dr. Waterloo, Ontario N2V 1C6

Date Printed: 6/19/2009

CUSTOMER

Pressure Vessel Engineering
120-Randall Drive, Suite B
Waterloo, ON N2V 1C6

VESSEL LOCATION

Pressure Vessel Engineering
120-Randall Drive, Suite B
Waterloo, ON N2V 1C6

VESSEL DESCRIPTION

Vertical Vessel with Bolted Cover

Vessel designed per the ASME Boiler & Pressure Vessel Code,
Section VIII, Division 1, 2007 Edition, 2008 Addenda
with Advanced Pressure Vessel, Version: 10.1.5
Vessel is ASME Code Stamped

Job No: PVE Sample 14
Vessel Number: 2

NAMEPLATE INFORMATION

Vessel MAWP: 125.00 PSI at 200 °F
MDMT: -20 °F at 125.00 PSI

Serial Number(s): _____

National Board Number(s): _____

Year Built: 2009

Radiography: NONE

Postweld Heat Treated: NONE

Construction Type: W

Signatures

Mechanical Technologist: _____ Date: ____/____/____
Cameron Moore

P.Eng: _____ Date: ____/____/____
Laurence Brundret

Table of Contents

Shell 1	1
Head 1	2
Nozzle 1	3
Nozzle 2	8
Threaded Coupling - 1"	11
Threaded Coupling - 2"	13
Leg Information	16
ASME Flanges	25
MDMT Summary	26
MAWP Summary	27
Summary Information	28
Hydrostatic Test Information Par. UG-99(b)	29

Pressure Vessel Engineering, Ltd.

Shell 1

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 1

Vessel Number: 2

Mark Number: S1

Date Printed: 6/19/2009

Cylindrical Shell Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	1.95 PSI	Long. Joint Efficiency:	70 %
Shell Material:	SA-516 Gr. 70	Factor B Chart:	CS-2
Shell Length:	41.8100 in.	Material Stress (hot):	20000 PSI
Corrosion Allowance:	0.0625 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Compressive Stress:	13116 PSI
Outside Diameter (new):	36.0000 in.	Actual Circumferential Stress:	17338 PSI
Outside Diameter (corroded):	36.0000 in.	Actual Longitudinal Stress:	8578 PSI
Shell Surface Area:	32.84 Sq. Ft.	Specific Gravity:	1.00
Shell Estimated Volume:	179.17 Gal.	Weight of Fluid:	1496.79 lb.
Circ. Joint Efficiency:	70 %	Total Flooded Shell Weight:	1825.50 lb.
		Shell Weight:	328.70 lb.

Minimum Design Metal Temperature Data

Min. Temperature Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	No	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-20 °F

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{126.95 * 17.8125}{2 * 20000 * 0.70 + 0.4 * 126.95}$$

= Greater Of (0.0806(Calculated), 0.0938(Minimum Allowed)) + 0.0625 (corrosion) + 0.0000 (ext. corrosion) = minimum of **0.1563 in.**

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{126.95 * 18.0000}{20000 * 0.70 + 0.4 * 126.95} = 0.1627 + 0.0625 (corrosion) + 0.0000 (ext. corrosion)$$

= minimum of **0.2252 in.**

Extreme Fiber Elongation Calculation per Paragraph UCS-79

$$\text{Elongation} = \frac{50t}{Rf} = \frac{50 * 0.2500}{17.8750}$$

= elongation of **0.70 %**

External loads do not control design.

Nominal Shell Thickness Selected = 0.2500 in.

Pressure Vessel Engineering, Ltd.

Head 1

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 1

Vessel Number: 2

Mark Number: H1

Date Printed: 6/19/2009

Ellipsoidal Head Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	1.95 PSI	Joint Efficiency:	85 %
Head Material:	SA-516 Gr. 70	Factor B Chart:	CS-2
Corrosion Allowance:	0.0625 in.	Material Stress (hot):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Material Stress (cold):	20000 PSI
Head Location:	Bottom	Actual Head Stress:	16308 PSI
Outside Diameter :	36.0000 in.	Straight Flange :	2.0000 in.
Thin Out :	0.0240 in.	Head Depth (ho) :	9.1250 in.

$$K = \frac{1}{6} [2 + (D/2h)^2] : 1.00$$

Head Surface Area:	11.23 Sq. Ft.	Specific Gravity:	1.00
Head Estimated Volume:	33.93 Gal.	Weight of Fluid:	282.94 lb.
Head Weight:	113.24 lb.	Total Flooded Head Weight:	396.18 lb.

Minimum Design Metal Temperature Data

Min. Temperature Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	No	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-20 °F

Design Thickness Calculations

Design Thickness Calculations per Appendix 1-4(c)

$$t = \frac{PD_0K}{2SE + 2P(K - 0.1)} = \frac{126.95 * 36.0000 * 1.00}{2 * 20000 * 0.85 + 2 * 126.95 * (1.00 - 0.1)}$$

= 0.1336 + 0.0625 (corrosion) + 0.0000 (ext. corrosion) + 0.0240(thin out) = minimum of **0.2201 in.**

Extreme Fiber Elongation Calculation per Paragraph UCS-79

$$\text{elongation} = \frac{75t}{R_f} = \frac{75 * 0.2500}{6.0775} = \text{elongation of } \mathbf{3.09 \%}$$

Nominal Head Thickness Selected = **0.2500 in.**
 Minimum Thickness after forming, t_s (uncorroded) = **0.2260 in.**

Pressure Vessel Engineering, Ltd.

Nozzle 1

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 1

ID Number: 1

Vessel Number: 2

Mark Number: N1

Date Printed: 6/19/2009

Nozzle Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	1.95 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	14.5000 in.	Allowable Stress at Design Temperature (S _n):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	18	Nozzle Pipe Schedule:	40
Nozzle ID (new):	16.8760 in.	Nozzle Wall Thickness(new):	0.5620 in.
Nozzle ID (corroded):	17.0010 in.	Nozzle Wall Thickness(corroded):	0.4995 in.
Outer "h" Limit:	0.4688 in.	Upper Weld Leg Size(Weld 41):	0.2500 in.
Internal "h" Limit:	0.0000 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	34.0020 in.	Outside Groove Weld Depth:	0.2227 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Reinforcing Pad Information

Reinforcing Material:	SA-516 Gr. 70	Allowable Stress at Design Temperature(S _p):	20000 PSI
		Allowable Stress at Ambient Temperature:	20000 PSI
Reinforcing Plate Thickness(t _e):	0.2500 in.	Repad to Vessel Weld Leg Size(Weld 42):	0.2500 in.
OD, Reinforcing Plate(D _p):	23.0000 in.	Repad to Nozzle Groove Weld Depth:	0.2500 in.

Host Component: Shell 1 - Shell 1

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.2500 in.
Material Stress(S _v):	20000 PSI	Shell wall thickness(corroded):	0.1875 in.

Nozzle Detail Information

Upper Weld Leg Size(Weld 41): 0.2500 in.

Nozzle Wall Thickness(t_n): 0.5620 in.

Outside Groove Weld Depth: 0.2227 in.

Repad to Vessel Weld Leg Size(Weld 42): 0.2500 in.

Repad Thickness(t_e): 0.2500 in.




Fig. UW-16.1 (j)

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 18 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

Nozzle 1

Job No: PVE Sample 14
Number: 1
ID Number: 1

Vessel Number: 2
Mark Number: N1

Date Printed: 6/19/2009

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{126.95 * 18.0000}{20000 * 1 + 0.4 * 126.95} = \mathbf{0.1140 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{126.95 * 8.5005}{17100 * 1 - 0.6 * 126.95} = \mathbf{0.0634 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550 \quad f_{r2} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550$$

$$f_{r3} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550 \quad f_{r4} = \min\left(\frac{S_p}{S_v}, 1.0000\right) = \min\left(\frac{20000}{20000}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. } C_a = \frac{126.95 * 8.5005}{17100 * 1.00 - 0.6 * 126.95} + 0.0625 + 0.0000 = \mathbf{0.1259 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. } C_a = \frac{126.95 * 18.0000}{20000 * 1 + 0.4 * 126.95} + 0.0625 + 0.0000 = \mathbf{0.1765 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + C_a + \text{ext. } C_a = \mathbf{0.3906 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.1765 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.4917}$ is greater than or equal to UG-45 value of $\mathbf{0.1765}$

Pressure Vessel Engineering, Ltd.

Nozzle 1

Job No: PVE Sample 14
Number: 1
ID Number: 1

Vessel Number: 2
Mark Number: N1

Date Printed: 6/19/2009

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

$$A = d \text{ tr } F + 2 \text{ tn tr } F (1 - \text{fr1}) = (17.0010 * 0.1140 * 1.00) + (2 * 0.4995 * 0.1140 * 1.00 * (1 - 0.8550)) = 1.9546 \text{ sq. in.}$$

Area Available - Internal Pressure

$$A1 \text{ Formula 1} = d(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - \text{fr1}) =$$

$$17.0010 * (1.00 * 0.1875 - 1.00 * 0.1140) - 2 * 0.4995 * (1.00 * 0.1875 - 1.00 * 0.1140) * (1 - 0.8550) = 1.2389 \text{ sq. in.}$$

$$A1 \text{ Formula 2} = 2(\text{t} + \text{tn})(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - \text{fr1}) =$$

$$2 * (0.1875 + 0.4995)(1.00 * 0.1875 - 1.00 * 0.1140) - 2 * 0.4995 * (1.00 * 0.1875 - 1.00 * 0.1140) * (1 - 0.8550)$$

$$= 0.0903 \text{ sq. in.}$$

$$A1 = \text{Larger value of } A1 \text{ Formula 1 and } A1 \text{ Formula 2} = 1.2389 \text{ sq. in.}$$

$$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(0.4995 - 0.0634) * 0.8550 * 0.1875 = 0.3496 \text{ sq. in.}$$

$$A2 \text{ Formula 2} = 2(\text{tn} - \text{trn}) \text{ fr2} (2.5 \text{ tn} + \text{te}) = 2(0.4995 - 0.0634) * 0.8550 * (2.5 * 0.4995 + 0.2500) = 1.1177 \text{ sq. in.}$$

$$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = 0.3496 \text{ sq. in.}$$

A3 = Smaller value of the following :

$$5 * t * t_i * f_{r2} = 5 * 0.1875 * 0.0000 * 0.8550 = 0.0000 \text{ sq. in.}$$

$$5 * t_i * t_i * f_{r2} = 5 * 0.0000 * 0.0000 * 0.8550 = 0.0000 \text{ sq. in.}$$

$$2 * h * t_i * f_{r2} = 2 * 0.0000 * 0.0000 * 0.8550 = 0.0000 \text{ sq. in.}$$

$$= 0.0000 \text{ sq. in.}$$

$$A41 = \text{Allowable Weld 41 area} * \text{fr3} = 0.0615 * 0.8550$$

$$= 0.0526 \text{ sq. in.}$$

$$A42 = (\text{leg})^2 * \text{fr4} = (0.2500)^2 * 1.0000$$

$$= 0.0625 \text{ sq. in.}$$

$$A43 = (\text{leg})^2 * \text{fr2} = 0 * 0.8550$$

$$= 0.0000 \text{ sq. in.}$$

$$A5 = (D_p - d - 2\text{tn}) \text{ te fr4} = (23.0000 - 17.0010 - 2 * 0.4995) * 0.2500 * 1.0000$$

$$= 1.2500 \text{ sq. in.}$$

Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A42 + A43 + A5 = 2.9536 sq. in., which is **greater** than A (1.9546)

Pressure Vessel Engineering, Ltd.

Nozzle 1

Job No: PVE Sample 14
 Number: 1
 ID Number: 1

Vessel Number: 2
 Mark Number: N1

Date Printed: 6/19/2009

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16 (Corroded Condition)

Weld 41 tmin = smaller of 0.75, te, or tn = smaller of 0.75, 0.2500, or 0.4995 = **0.2500 in.**

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.1750}{0.7}$ = **0.2500 in.**

Weld 41, actual weld leg = **0.2500 in.**

Weld 42 tmin = smaller of 0.75, t, or te = smaller of 0.75, 0.1875, or 0.2500 = **0.1875 in.**

Weld 42 Leg min. = $\frac{0.5 * t_{\min} + \text{ext. CA}}{0.7} = \frac{0.5 * 0.1875 + 0.0000}{0.7}$ = **0.1339 in.**

Weld 42, actual weld leg = **0.2500 in.**

Unit Stresses per Paragraphs UG-45(c) and UW-15

Nozzle wall in shear = 0.70 * Sn = 0.70 * 17100 = **11970 PSI**

Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 17100 = **8379 PSI**

Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100 = **12654 PSI**

Outer fillet, Weld 42, in shear = 0.49 * Material Stress = 0.49 * 20000 = **9800 PSI**

Repad groove weld, in tension = 0.74 * Material Stress = 0.74 * 17100 = **12654 PSI**

Strength of Connection Elements

Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} =$
 $\frac{1}{2} * \pi * 17.5005 * 0.4995 * 11970$ = **164300 lb.**

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 18.0000 * 0.2500 * 8379$ = **59200 lb.**

Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} =$
 $\frac{1}{2} * \pi * 18.0000 * 0.1875 * 12654$ = **67100 lb.**

Outer fillet in shear = $\frac{1}{2} * \pi * \text{Plate OD} * \text{weld leg} * \text{outer fillet in shear unit stress} = \frac{1}{2} * \pi * 23.0000 * 0.2500 * 9800$ = **88500 lb.**

Repad groove weld = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{Groove Depth} * \text{repad groove weld in tension unit stress} =$
 $\frac{1}{2} * \pi * 18.0000 * 0.2500 * 12654$ = **89400 lb.**

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [1.9546 - 1.2389 + 2 * 0.4995 * 0.8550 * (1.00 * 0.1875 - 1.0000 * 0.1140)] * 20000 = **15600 lb.**

W1-1 = (A2 + A5 + A41 + A42) * Sv = (0.3496 + 1.2500 + 0.0526 + 0.0625) * 20000 = **34300 lb.**

W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (0.3496 + 0.0000 + 0.0526 + 0.0000 + 2 * 0.4995 * 0.1875 * 0.8550) * 20000 = **11200 lb.**

W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv =
 (0.3496 + 0.0000 + 1.2500 + 0.0526 + 0.0625 + 0.0000 + 2 * 0.4995 * 0.1875 * 0.8550) * 20000 = **37500 lb.**

Check Strength Paths

Path 1-1 = Outer fillet in shear + Nozzle wall in shear = 88500 + 164300 = **252800 lb.**

Path 2-2 = Upper fillet in shear + Repad groove weld + Groove weld in tension + Inner fillet in shear =
 59200 + 89400 + 67100 + 0 = **215700 lb.**

Path 3-3 = Outer fillet in shear + Inner fillet in shear + Groove weld in tension = 88500 + 0 + 67100 = **155600 lb.**

Pressure Vessel Engineering, Ltd.

Nozzle 1

Job No: PVE Sample 14
Number: 1
ID Number: 1

Vessel Number: 2
Mark Number: N1

Date Printed: 6/19/2009

Plate Strength = $A5 * Sp = 1.2500 * 20000$

= **25000 lb.**

Outer fillet weld strength(88500) is greater than plate strength(25000).

Pressure Vessel Engineering, Ltd.

Nozzle 2

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 2

ID Number: 2

Vessel Number: 2

Mark Number: N2

Date Printed: 6/19/2009

Nozzle Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	1.95 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-106 Gr. B	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	11.0000 in.	Allowable Stress at Design Temperature (S _n):	17100 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	17100 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	4	Nozzle Pipe Schedule:	40
Nozzle ID (new):	4.0260 in.	Nozzle Wall Thickness(new):	0.2370 in.
Nozzle ID (corroded):	4.1510 in.	Nozzle Wall Thickness(corroded):	0.1745 in.
Outer "h" Limit:	0.4363 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
Internal "h" Limit:	0.2800 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	9.5863 in.	Outside Groove Weld Depth:	0.2500 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Shell 1 - Shell 1

Material:	SA-516 Gr. 70	Shell wall thickness(new):	0.2500 in.
Material Stress(S _v):	20000 PSI	Shell wall thickness(corroded):	0.1875 in.

Nozzle Detail Information

Backing strip if used may be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2370 in.

Outside Groove Weld Depth: 0.2500 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 4 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

Nozzle 2

Job No: PVE Sample 14
Number: 2
ID Number: 2

Vessel Number: 2
Mark Number: N2

Date Printed: 6/19/2009

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{P R_o}{S E + 0.4 P} = \frac{126.95 * 18.0000}{20000 * 1 + 0.4 * 126.95} = \mathbf{0.1140 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{P R_n}{S E - 0.6 P} = \frac{126.95 * 2.0755}{17100 * 1 - 0.6 * 126.95} = \mathbf{0.0155 \text{ in.}}$$

Strength Reduction Factors

$$f_{r1} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550 \quad f_{r2} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550$$

$$f_{r3} = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{17100}{20000}, 1.0000\right) = 0.8550$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{P R_n}{S E - 0.6 P} + C_a + \text{ext. } C_a = \frac{126.95 * 2.0755}{17100 * 1.00 - 0.6 * 126.95} + 0.0625 + 0.0000 = \mathbf{0.0780 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{P R_o}{S E + 0.4 P} + C_a + \text{ext. } C_a = \frac{126.95 * 18.0000}{20000 * 1 + 0.4 * 126.95} + 0.0625 + 0.0000 = \mathbf{0.1765 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + C_a + \text{ext. } C_a = \mathbf{0.2699 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.1765 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.2074}$ is greater than or equal to UG-45 value of $\mathbf{0.1765}$

Pressure Vessel Engineering, Ltd.

Nozzle 2

Job No: PVE Sample 14
Number: 2
ID Number: 2

Vessel Number: 2
Mark Number: N2

Date Printed: 6/19/2009

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

$$A = d \text{ tr } F + 2 \text{ tn tr } F (1 - \text{fr1}) = (4.7932 * 0.1140 * 1.00) + (2 * 0.1745 * 0.1140 * 1.00 * (1 - 0.8550)) = \mathbf{0.5522 \text{ sq. in.}}$$

Area Available - Internal Pressure

$$A1 \text{ Formula 1} = d(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - \text{fr1}) = 4.7932 * (1.00 * 0.1875 - 1.00 * 0.1140) - 2 * 0.1745 * (1.00 * 0.1875 - 1.00 * 0.1140) * (1 - 0.8550) = 0.3486 \text{ sq. in.}$$

$$A1 \text{ Formula 2} = 2(t + \text{tn})(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - \text{fr1}) = 2 * (0.1875 + 0.1745)(1.00 * 0.1875 - 1.00 * 0.1140) - 2 * 0.1745 * (1.00 * 0.1875 - 1.00 * 0.1140) * (1 - 0.8550)$$

$$= 0.0495 \text{ sq. in.}$$

$$A1 = \text{Larger value of } A1 \text{ Formula 1 and } A1 \text{ Formula 2} = \mathbf{0.3486 \text{ sq. in.}}$$

$$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(0.1745 - 0.0155) * 0.8550 * 0.1875 = 0.1274 \text{ sq. in.}$$

$$A2 \text{ Formula 2} = 5(\text{tn} - \text{trn}) \text{ fr2 tn} = 5(0.1745 - 0.0155) * 0.8550 * 0.1745 = 0.1186 \text{ sq. in.}$$

$$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = \mathbf{0.1186 \text{ sq. in.}}$$

A3 = Smaller value of the following :

$$5 * t * t_i * f_{r2} = 5 * 0.1875 * 0.1120 * 0.8550 = 0.0898 \text{ sq. in.}$$

$$5 * t_i * t_i * f_{r2} = 5 * 0.1120 * 0.1120 * 0.8550 = 0.0536 \text{ sq. in.}$$

$$2 * h * t_i * f_{r2} = 2 * 0.0000 * 0.1120 * 0.8550 = 0.0000 \text{ sq. in.}$$

$$= \mathbf{0.0000 \text{ sq. in.}}$$

$$A41 = (\text{leg})^2 * \text{fr2} = (0.3750)^2 * 0.8550 = \mathbf{0.1202 \text{ sq. in.}}$$

$$A43 = (\text{leg})^2 * \text{fr2} = 0 * 0.8550 = \mathbf{0.0000 \text{ sq. in.}}$$

Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A43 = 0.5874 sq. in., which is **greater** than A (0.5522)

Pressure Vessel Engineering, Ltd.

Threaded Coupling - 1"

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 3

ID Number: 3

Vessel Number: 2

Mark Number: N3

Date Printed: 6/19/2009

Nozzle Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	1.95 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-105	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	1.1900 in.	Allowable Stress at Design Temperature (S _n):	20000 PSI
		Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle ID (new):	1.3300 in.	Nozzle Wall Thickness(new):	0.2175 in.
Nozzle ID (corroded):	1.4550 in.	Nozzle Wall Thickness(corroded):	0.1550 in.
Outer "h" Limit:	0.3875 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
OD, Limit of Reinforcement:	2.9100 in.		

Minimum Design Metal Temperature


Min. Temp. Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Head 1 - Head 1

Material:	SA-516 Gr. 70	Head wall thickness(new):	0.2500 in.
Material Stress(S _v):	20000 PSI	Head wall thickness - thin out (corroded):	0.1635 in.

Abutting Fillet

Nozzle Detail Information



Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.2175 in.

Nozzle abuts the vessel, attached by a fillet weld.
 Nozzle is adequate for UG-45 requirements.
 Opening is adequately reinforced for Internal Pressure.
 Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.
 Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

Threaded Coupling - 1"

Job No: PVE Sample 14
Number: 3
ID Number: 3

Vessel Number: 2
Mark Number: N3

Date Printed: 6/19/2009

Required Head Thickness per Paragraph UG-37(a)

$$t_r = \frac{P K_1 D_o}{(2SE + 0.8P)} = \frac{126.95 * 0.9000 * 36.0000}{(2 * 20000 * 1 + 0.8 * 126.95)} = \mathbf{0.1026 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{PR_n}{SE - 0.6P} = \frac{126.95 * 0.7275}{20000 * 1 - 0.6 * 126.95} = \mathbf{0.0046 \text{ in.}}$$

Strength Reduction Factors

$$fr_2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{20000}{20000}, 1.0000\right) = 1.0000 \quad fr_3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{20000}{20000}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PR_n}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{126.95 * 0.7275}{20000 * 1.00 - 0.6 * 126.95} + 0.0625 + 0.0000 = \mathbf{0.0671 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{P K D_o}{(2SE + 2P(K - 0.1))} + Ca + \text{ext. Ca} = \frac{126.95 * 1.0000 * 36.0000}{(2 * 20000 * 1 + 2 * 126.95 * (1.0000 - 0.1))} + 0.0625 + 0.0000 = \mathbf{0.1761 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = \mathbf{0.1894 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.1761 \text{ in.}}$$

Wall thickness = $t_n = \mathbf{0.2175}$ is greater than or equal to UG-45 value of $\mathbf{0.1761}$

Pressure Vessel Engineering, Ltd.

Threaded Coupling - 2"

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Number: 4

ID Number: 4

Vessel Number: 2

Mark Number: N4

Date Printed: 6/19/2009

Nozzle Design Information

Design Pressure:	125.00 PSI	Design Temperature:	200 °F
Static Head:	0.00 PSI	Nozzle Efficiency (E):	100 %
Nozzle Material:	SA-105	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	CS-2
External Projection:	1.6900 in.	Allowable Stress at Design Temperature (S _n):	20000 PSI
		Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0625 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle ID (new):	2.3750 in.	Nozzle Wall Thickness(new):	0.3125 in.
Nozzle ID (corroded):	2.5000 in.	Nozzle Wall Thickness(corroded):	0.2500 in.
Outer "h" Limit:	0.6250 in.	Upper Weld Leg Size(Weld 41):	0.3750 in.
OD, Limit of Reinforcement:	11.0000 in.	Outside Groove Weld Depth:	0.3125 in.

Minimum Design Metal Temperature

Min. Temp. Curve:	B	Pressure at MDMT:	125.00 PSI
UCS-66(b) reduction:	Yes	Minimum Design Metal Temperature:	-20 °F
UCS-68(c) reduction:	No	Computed Minimum Temperature:	-155 °F

Host Component: Flange 1 - 36" Blind Flange

Material:	SA-105	Host Flange wall thickness(new):	4.0000 in.
Material Stress(S _v):	20000 PSI	Host Flange wall thickness(corroded):	4.0000 in.

Nozzle Detail Information

Upper Weld Leg Size(Weld 41): 0.3750 in.

Nozzle Wall Thickness(t_n): 0.3125 in.

Outside Groove Weld Depth: 0.3125 in.




Fig. UW-16.1 (b)

Nozzle abuts the vessel, attached by a groove weld.
 Nozzle is adequate for UG-45 requirements.
 Opening is adequately reinforced for Internal Pressure.
 Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

Threaded Coupling - 2"

Job No: PVE Sample 14
Number: 4
ID Number: 4

Vessel Number: 2
Mark Number: N4

Date Printed: 6/19/2009

Required Host Flange Thickness per Paragraph UG-39(b)(1)

$$tr = G * \sqrt{\frac{CP}{SE} + \frac{1.9 W_{m1} h_G}{SE G^3}} = 38.0000 * \sqrt{\frac{0.3000 * 125.00}{20000 * 1} + \frac{1.9 * 141764 * 0.5000}{20000 * 1 * 38.0000^3}} = 1.6984 \text{ in.}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$trn = \frac{PRn}{SE - 0.6P} = \frac{125.00 * 1.2500}{20000 * 1 - 0.6 * 125.00} = 0.0078 \text{ in.}$$

Strength Reduction Factors

$$fr2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{20000}{20000}, 1.0000\right) = 1.0000 \quad fr3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{20000}{20000}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PRn}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{125.00 * 1.2500}{20000 * 1.00 - 0.6 * 125.00} + 0.0625 + 0.0000 = 0.0703 \text{ in.}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = G * \sqrt{\frac{CP}{SE} + \frac{1.9 W_{m1} h_G}{SE G^3}} + Ca + \text{ext. Ca} = 38.0000 * \sqrt{\frac{0.3000 * 125.00}{20000 * 1} + \frac{1.9 * 141764 * 0.5000}{20000 * 1 * 38.0000^3}} + 0.0625 + 0.0000 = 1.7609 \text{ in.}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = 0.2515 \text{ in.}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = 0.2515 \text{ in.}$$

Wall thickness = $t_n = 0.3125$ is greater than or equal to UG-45 value of 0.2515

Pressure Vessel Engineering, Ltd.

Threaded Coupling - 2"

Job No: PVE Sample 14
Number: 4
ID Number: 4

Vessel Number: 2
Mark Number: N4

Date Printed: 6/19/2009

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

A = $0.5 d t r = (0.5 * 2.5000 * 1.6984)$ = **2.1230** sq. in.

Area Available - Internal Pressure

A1 Formula 1 = $d(E1 t - F t r) =$
 $2.5000 * (1.00 * 4.0000 - 1.00 * 1.6984) = 5.7540$ sq. in.

A1 Formula 2 = $2(t + t_n)(E1 t - F t r) =$
 $2 * (4.0000 + 0.2500)(1.00 * 4.0000 - 1.00 * 1.6984) = 19.5636$ sq. in.

A1 = Larger value of *A1 Formula 1* and *A1 Formula 2* = **19.5636** sq. in.

A2 Formula 1 = $5(t_n - t_{rn}) f r_2 t = 5(0.2500 - 0.0078) * 1.0000 * 4.0000 = 4.8440$ sq. in.

A2 Formula 2 = $5(t_n - t_{rn}) f r_2 t_n = 5(0.2500 - 0.0078) * 1.0000 * 0.2500 = 0.3028$ sq. in.

A2 = Smaller value of *A2 Formula 1* and *A2 Formula 2* = **0.3028** sq. in.

A41 = $(leg)^2 * f r_2 = (0.3750)^2 * 1.0000$ = **0.1406** sq. in.

Area Available (Internal Pressure) = **A1 + A2 + A41 = 20.0070** sq. in., which is **greater** than **A (2.1230)**

Pressure Vessel Engineering, Ltd.

Leg 1

Customer: **Pressure Vessel Engineering**
Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Leg Information

Design Temperature:	200 °F	Factor B Chart:	CS-2
Material:	SA-36	Material Stress (Hot):	16600 PSI
Condition:		Material Stress (Cold):	16600 PSI
B.P. to Vessel Attachment Length (L):	6.0000 in.	Modulus of Elasticity:	28.6 10 ⁶ PSI
Direction of Applied Force:	0 °	Yield Strength:	33000 PSI
Length of Supports:	31.0000 in.	Dist. From Reference Line:	6.0000 in.
Quantity:	4	Method of Attachment:	Leg In
Type:	Angle	Molded to Head Curvature:	No
Description:	3 x 3 x 1/4	t ₁ :	0.2500 in.
d ₁ :	3.0000 in.	t ₂ :	0.2500 in.
d ₂ :	3.0000 in.	Side (W _s):	6.0000 in.
Weld Attachment Length Top (W _t):	3.0000 in.		
Weld Leg Dimension (W _l):	0.2500 in.		

Base Plate Information

Design Temperature:	200 °F	Material Stress (Hot):	16600 PSI
Material:	SA-36	Material Stress (Cold):	16600 PSI
Condition:		Yield Strength:	33000 PSI
Length:	6.0000 in.	Thickness:	0.2500 in.
Width:	6.0000 in.	Bending Coefficient (C _m):	1.0000
Leg to B.P. Attachment Factor:	0.7500		
Effective Length Factor (K):	1.5000		

Anchor Bolt Information

Material:	SA-193 Gr. B7	Material Stress (Hot):	25000 PSI
Condition:		Material Stress (Cold):	25000 PSI
Diameter:	0.7500 in.	Root Area:	0.3020 sq. in.
Quantity:	4	Bolt Circle Diameter:	36.0000 in.
Ultimate 28 Day Concrete Strength:	3000 PSI		

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Operating Pressurized Condition - Sustained Loads

Support Leg Properties

$$\text{Section Modulus, } S_x = \frac{I_x}{C_x} = \frac{1.9840}{2.1213} = 0.9353 \text{ in.}^3$$

$$\text{Section Modulus, } S_y = \frac{I_y}{C_y} = \frac{0.5044}{1.1913} = 0.4234 \text{ in.}^3$$

$$\text{Radius of gyration, } r_x = \sqrt{\frac{I_x}{A}} = \sqrt{\frac{1.9840}{1.4375}} = 1.1748 \text{ in.}$$

$$\text{Radius of gyration, } r_y = \sqrt{\frac{I_y}{A}} = \sqrt{\frac{0.5044}{1.4375}} = 0.5924 \text{ in.}$$

$$\text{Least radius of gyration, } r_{\min} = \sqrt{\frac{I_{\min}}{A}} = \sqrt{\frac{0.5044}{1.4375}} = 0.5924 \text{ in.}$$

$$\text{Slenderness ratio, } SR_x = \frac{K L}{r_x} = \frac{1.5000 * 6.0000}{1.1748} = 7.6609$$

$$\text{Slenderness ratio, } SR_y = \frac{K L}{r_y} = \frac{1.5000 * 6.0000}{0.5924} = 15.1924$$

$$SR_{\max} = \frac{K L}{r_{\min}} = \frac{1.5000 * 6.0000}{0.5924} = 15.1924$$

$$\text{Critical slenderness ratio, } C_c = \sqrt{\frac{2 \pi^2 E}{F_y}} = \sqrt{\frac{2 * \pi^2 * (28.6 * 10^6)}{33000}} = 130.79$$

$$F'_{ex} = \frac{12 \pi^2 E}{23 SR_x^2} = \frac{12 * \pi^2 * (28.6 * 10^6)}{23 * 7.6609^2} = 2509341 \text{ PSI}$$

$$F'_{ey} = \frac{12 \pi^2 E}{23 SR_y^2} = \frac{12 * \pi^2 * (28.6 * 10^6)}{23 * 15.1924^2} = 638067 \text{ PSI}$$

For $SR_{\max} \leq C_c$, Allowable compressive stress:

$$F_a = \frac{\left(1 - \frac{SR_{\max}^2}{2 C_c^2}\right) F_y}{\frac{5}{3} + \frac{3 SR_{\max}}{8 C_c} - \frac{SR_{\max}^3}{8 C_c^3}} = \frac{\left(1 - \frac{15.1924^2}{2 * 130.79^2}\right) * 33000}{\frac{5}{3} + \frac{3 * 15.1924}{8 * 130.79} - \frac{15.1924^3}{8 * 130.79^3}} = 19168 \text{ PSI}$$

Allowable bending stress: $S_b = 0.6 F_y = 0.6 * 33000 = 19800 \text{ PSI}$

Allowable tension stress: $S_t = 0.6 F_y = 0.6 * 33000 = 19800 \text{ PSI}$

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Leg to Vessel Weld Properties

Distance between welds along side of legs (b) = **= 3.8891 in.**

$L_w = (2 W_s) + W_t = (2 * 6.0000) + 3.0000$ **= 15.0000 in.**

$I_{wy} = \frac{W_s^3 (2 W_t + W_s)}{3 L_w} = \frac{6.0000^3 * (2 * 3.0000 + 6.0000)}{3 * 15.0000}$ **= 57.6000 in.³**

$I_{wz} = \frac{6 W_s b^2 + W_t^3}{12} = \frac{6 * 6.0000 * 3.8891^2 + 3.0000^3}{12}$ **= 47.6250 in.³**

$J_{wx} = I_{wy} + I_{wz} = 57.6000 + 47.6250$ **= 105.2250 in.³**

Distance from weld neutral axis to top of welds:

$EF_{yt} = \frac{W_s^2}{L_w} = \frac{6.0000^2}{15.0000}$ **= 2.4000 in.**

Distance from weld neutral axis to bottom of welds:

$EF_{yb} = W_s - EF_{yt} = 6.0000 - 2.4000$ **= 3.6000 in.**

Distance from weld neutral axis to side of welds:

$EF_z = \text{MAX} \left(\frac{b}{2}, \frac{W_t}{2} \right) = \text{MAX} \left(\frac{3.8891}{2}, \frac{3.0000}{2} \right)$ **= 1.9445 in.**

NO Wind Analysis Information

Wind Analysis Calculations

No Wind Load Calculations were performed

NO Seismic Design Information

Seismic Analysis Calculations

No Seismic Analysis Calculations were performed.

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Loadings and Stresses on Support Legs

Direction of Applied Force = 0 °

Leg Orientation °	Moment of Inertia in.^4	Lateral Force lb.	Axial Stress PSI	Bending Stresses (f _{bx}) PSI	Bending Stresses (f _{by}) PSI	Acceptance Ratio (Eqn ₁)	Acceptance Ratio (Eqn ₂)
0	0.5044	0	-77	0	260	0.0171	
90	1.9840	0	-77	0	260	0.0171	
180	0.5044	0	-77	0	260	0.0171	
270	1.9840	0	-77	0	260	0.0171	

Direction of Worst case Force = 0 °
Highest Stress Ratio = 0.0171

Loadings and Stresses on Leg to Vessel attachment welds

Leg Orientation °	Load F _x lb.	Load F _y lb.	Load F _z lb.	Moment M _x in.-lb.	Moment M _y in.-lb.	Moment M _z in.-lb.	Total Stress PSI	Stress Ratio
0	0	0	-110	0	-110	0	40	0.0049
90	0	0	-110	0	-110	0	40	0.0049
180	0	0	-110	0	-110	0	40	0.0049
270	0	0	-110	0	-110	0	40	0.0049

Direction of Worst case Force = 0 °
Highest Stress Ratio: 0.0049

Loadings and Pressure on Concrete Foundation

Direction of applied force: = 0 °

Leg Orientation °	Bearing Pressure PSI	Moment M _x in.-lb.	Moment M _y in.-lb.	Maximum Pressure P _x PSI	Maximum Pressure P _y PSI	Max. Concrete Pressure PSI	Concrete Pressure Ratio
0	3	78	78	2.17	2.17	7.39	0.0082
90	3	78	78	2.17	2.17	7.39	0.0082
180	3	78	78	2.17	2.17	7.39	0.0082
270	3	78	78	2.17	2.17	7.39	0.0082

Direction of Worst case Force: = 0 °
Highest Stress Ratio = 0.0082

Loadings and Stresses on BasePlate and Anchor bolts

Leg Orientation °	Moment M _x in.-lb.	Moment M _y in.-lb.	Maximum Pressure P _x PSI	Maximum Pressure P _y PSI	Maximum B.P. Stress PSI	BasePlate Stress Ratio	Anchor Bolt Stress PSI	Anchor Bolt Stress Ratio
0	10	10	966	919	1333	0.0673	3	0.0001
90	10	10	966	919	1333	0.0673	3	0.0001
180	10	10	966	919	1333	0.0673	3	0.0001
270	10	10	966	919	1333	0.0673	3	0.0001

Direction of Worst case Force: = 0 °
Highest Stress Ratio = 0.0673

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Maximum General Longitudinal Stresses

VE = 1.00 **1.00**

$$S_{L1} = \frac{M_a}{Z} - \frac{W VE}{A} + \left(\frac{P * D}{4 * t} \right) = \frac{0}{187.8903} - \frac{441.94 * 1.00}{21.10} + \left(\frac{126.95 * 36.0000}{4 * 0.1875} \right) = \mathbf{6073 \text{ PSI}}$$

$$S_{L2} = -\frac{M_a}{Z} - \frac{W VE}{A} = -\frac{0}{187.8903} - \frac{441.94 * 1.00}{21.10} = \mathbf{-21 \text{ PSI}}$$

Allowable Tension Stress, S_{ta} = S E = 20000 * 0.70 = 14000 PSI

Allowable Compressive Stress, S_{ca} = -B = -13116 = -13116 PSI

$$R_{SL1} = \frac{S_{L1}}{S_{ta}} = \frac{6073}{14000} = \mathbf{0.4338}$$

$$R_{SL2} = \frac{S_{L2}}{S_{ca}} = \frac{-21}{-13116} = \mathbf{0.0016}$$

Summary

Governing external force	= None
Total Force	= 0 lb.
Weight	= 441.94 lb.
Base Moment	= 0 in.-lb.
Tangent Moment	= 0 in.-lb.
Leg Stresses	
Maximum combined compressive and bending stress ratio	= 0.0171
Leg BasePlate	
Concrete Stress Ratio	= 0.0082
Base Plate Stress Ratio	= 0.0673
Host Stresses	
SI1 ratio	= 0.4338
SI2 ratio	= 0.0016
Weld Stresses	
Leg to vessel weld stress ratio	= 0.0049

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Test Conditions

Support Leg Properties

$$\text{Section Modulus, } S_x = \frac{I_x}{C_x} = \frac{1.9840}{2.1213} = 0.9353 \text{ in.}^3$$

$$\text{Section Modulus, } S_y = \frac{I_y}{C_y} = \frac{0.5044}{1.1913} = 0.4234 \text{ in.}^3$$

$$\text{Radius of gyration, } r_x = \sqrt{\frac{I_x}{A}} = \sqrt{\frac{1.9840}{1.4375}} = 1.1748 \text{ in.}$$

$$\text{Radius of gyration, } r_y = \sqrt{\frac{I_y}{A}} = \sqrt{\frac{0.5044}{1.4375}} = 0.5924 \text{ in.}$$

$$\text{Least radius of gyration, } r_{\min} = \sqrt{\frac{I_{\min}}{A}} = \sqrt{\frac{0.5044}{1.4375}} = 0.5924 \text{ in.}$$

$$\text{Slenderness ratio, } SR_x = \frac{K L}{r_x} = \frac{1.5000 * 6.0000}{1.1748} = 7.6609$$

$$\text{Slenderness ratio, } SR_y = \frac{K L}{r_y} = \frac{1.5000 * 6.0000}{0.5924} = 15.1924$$

$$SR_{\max} = \frac{K L}{r_{\min}} = \frac{1.5000 * 6.0000}{0.5924} = 15.1924$$

$$\text{Critical slenderness ratio, } C_c = \sqrt{\frac{2 \pi^2 E}{F_y}} = \sqrt{\frac{2 * \pi^2 * (28.6 * 10^6)}{33000}} = 130.79$$

$$F'_{ex} = \frac{12 \pi^2 E}{23 SR_x^2} = \frac{12 * \pi^2 * (28.6 * 10^6)}{23 * 7.6609^2} = 2509341 \text{ PSI}$$

$$F'_{ey} = \frac{12 \pi^2 E}{23 SR_y^2} = \frac{12 * \pi^2 * (28.6 * 10^6)}{23 * 15.1924^2} = 638067 \text{ PSI}$$

For $SR_{\max} \leq C_c$, Allowable compressive stress:

$$F_a = \frac{\left(1 - \frac{SR_{\max}^2}{2 C_c^2}\right) F_y}{\frac{5}{3} + \frac{3 SR_{\max}}{8 C_c} - \frac{SR_{\max}^3}{8 C_c^3}} = \frac{\left(1 - \frac{15.1924^2}{2 * 130.79^2}\right) * 33000}{\frac{5}{3} + \frac{3 * 15.1924}{8 * 130.79} - \frac{15.1924^3}{8 * 130.79^3}} = 19168 \text{ PSI}$$

Allowable bending stress: $S_b = 0.6 F_y = 0.6 * 33000 = 19800 \text{ PSI}$

Allowable tension stress: $S_t = 0.6 F_y = 0.6 * 33000 = 19800 \text{ PSI}$

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Leg to Vessel Weld Properties

Distance between welds along side of legs (b) = **= 3.8891 in.**

$L_w = (2 W_s) + W_t = (2 * 6.0000) + 3.0000$ **= 15.0000 in.**

$I_{wy} = \frac{W_s^3 (2 W_t + W_s)}{3 L_w} = \frac{6.0000^3 * (2 * 3.0000 + 6.0000)}{3 * 15.0000}$ **= 57.6000 in.³**

$I_{wz} = \frac{6 W_s b^2 + W_t^3}{12} = \frac{6 * 6.0000 * 3.8891^2 + 3.0000^3}{12}$ **= 47.6250 in.³**

$J_{wx} = I_{wy} + I_{wz} = 57.6000 + 47.6250$ **= 105.2250 in.³**

Distance from weld neutral axis to top of welds:

$EF_{yt} = \frac{W_s^2}{L_w} = \frac{6.0000^2}{15.0000}$ **= 2.4000 in.**

Distance from weld neutral axis to bottom of welds:

$EF_{yb} = W_s - EF_{yt} = 6.0000 - 2.4000$ **= 3.6000 in.**

Distance from weld neutral axis to side of welds:

$EF_z = \text{MAX} \left(\frac{b}{2}, \frac{W_t}{2} \right) = \text{MAX} \left(\frac{3.8891}{2}, \frac{3.0000}{2} \right)$ **= 1.9445 in.**

Wind load calculations are not required for the test condition.

Seismic load calculations are not required for the test condition.

Loadings and Stresses on Support Legs

Direction of Applied Force = **0 °**

Leg Orientation °	Moment of Inertia in.^4	Lateral Force lb.	Axial Stress PSI	Bending Stresses (f _{bx}) PSI	Bending Stresses (f _{by}) PSI	Acceptance Ratio (Eqn ₁)	Acceptance Ratio (Eqn ₂)
0	0.5044	0	-386	0	1313	0.0865	
90	1.9840	0	-386	0	1313	0.0865	
180	0.5044	0	-386	0	1313	0.0865	
270	1.9840	0	-386	0	1313	0.0865	

Direction of Worst case Force = **0 °**
Highest Stress Ratio = **0.0865**

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Loadings and Stresses on Leg to Vessel attachment welds

Leg Orientation °	Load F _x lb.	Load F _y lb.	Load F _z lb.	Moment M _x in.-lb.	Moment M _y in.-lb.	Moment M _z in.-lb.	Total Stress PSI	Stress Ratio
0	0	0	-555	0	-556	0	203	0.0250
90	0	0	-555	0	-556	0	203	0.0250
180	0	0	-555	0	-556	0	203	0.0250
270	0	0	-555	0	-556	0	203	0.0250

Direction of Worst case Force = 0 °
Highest Stress Ratio: 0.0250

Loadings and Pressure on Concrete Foundation

Direction of applied force: = 0 °

Leg Orientation °	Bearing Pressure PSI	Moment M _x in.-lb.	Moment M _y in.-lb.	Maximum Pressure P _x PSI	Maximum Pressure P _y PSI	Max. Concrete Pressure PSI	Concrete Pressure Ratio
0	15	393	393	10.92	10.92	37.25	0.0414
90	15	393	393	10.92	10.92	37.25	0.0414
180	15	393	393	10.92	10.92	37.25	0.0414
270	15	393	393	10.92	10.92	37.25	0.0414

Direction of Worst case Force: = 0 °
Highest Stress Ratio = 0.0414

Loadings and Stresses on BasePlate and Anchor bolts

Leg Orientation °	Moment M _x in.-lb.	Moment M _y in.-lb.	Maximum Pressure P _x PSI	Maximum Pressure P _y PSI	Maximum B.P. Stress PSI	BasePlate Stress Ratio	Anchor Bolt Stress PSI	Anchor Bolt Stress Ratio
0	51	48	4870	4634	6723	0.3395	14	0.0006
90	51	48	4870	4634	6723	0.3395	14	0.0006
180	51	48	4870	4634	6723	0.3395	14	0.0006
270	51	48	4870	4634	6723	0.3395	14	0.0006

Direction of Worst case Force: = 0 °
Highest Stress Ratio = 0.3395

Pressure Vessel Engineering, Ltd.

Leg 1

Job No: PVE Sample 14
Mark Number: LEG1

Vessel Number: 2

Date Printed: 6/19/2009

Maximum General Longitudinal Stresses

VE = 1.00 **1.00**

$$S_{L1} = \frac{M_a}{Z} - \frac{W VE}{A} + \left(\frac{P * D}{4 * t} \right) = \frac{0}{249.2165} - \frac{2220.09 * 1.00}{28.08} + \left(\frac{125.00 * 36.0000}{4 * 0.2500} \right) = 4421 \text{ PSI}$$

$$S_{L2} = -\frac{M_a}{Z} - \frac{W VE}{A} = -\frac{0}{249.2165} - \frac{2220.09 * 1.00}{28.08} = -79 \text{ PSI}$$

Allowable Tension Stress, S_{ta} = S E = 20000 * 0.70 = 14000 PSI

Allowable Compressive Stress, S_{ca} = -B = -13116 = -13116 PSI

$$R_{SL1} = \frac{S_{L1}}{S_{ta}} = \frac{4421}{14000} = 0.3158$$

$$R_{SL2} = \frac{S_{L2}}{S_{ca}} = \frac{-79}{-13116} = 0.0060$$

Summary

Governing external force	= None
Total Force	= 0 lb.
Weight	= 2220.09 lb.
Base Moment	= 0 in.-lb.
Tangent Moment	= 0 in.-lb.
Leg Stresses	
Maximum combined compressive and bending stress ratio	= 0.0865
Leg BasePlate	
Concrete Stress Ratio	= 0.0414
Base Plate Stress Ratio	= 0.3395
Host Stresses	
SI1 ratio	= 0.3158
SI2 ratio	= 0.0060
Weld Stresses	
Leg to vessel weld stress ratio	= 0.0250

Pressure Vessel Engineering, Ltd.

Vertical Vessel with Bolted Cover

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Vessel Number: 2

Date Printed: 6/19/2009

ASME Flange Design Information

Host	Description	Type	Size (in.)	Material	ASME Class	Material Group	MAP (PSI)
Nozzle 1	ASME Flange 1	Weld Neck	18	SA-105	150	1.1	260.00
Nozzle 2	4" Weld Neck Flange	Weld Neck	4	SA-105	150	1.1	260.00
Shell 1	36" Weld Neck Flange		36	SA-105	150	1.1	260.00
	36" Blind Flange		36	SA-105	150	1.1	260.00

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE Sample 14

Vessel Number: 2

Date Printed: 6/19/2009

MDMT Report by Components

Design MDMT is -20 °F

Component	Material	Curve	Pressure	MDMT
Shell 1	SA-516 Gr. 70	B	125.00 PSI	-20 °F
Nozzle 1	SA-106 Gr. B	B	125.00 PSI	-155 °F
Nozzle 2	SA-106 Gr. B	B	125.00 PSI	-155 °F
Head 1	SA-516 Gr. 70	B	125.00 PSI	-20 °F
Threaded Coupling - 1"	SA-105	B	125.00 PSI	-155 °F
36" Blind Flange	SA-105	B	125.00 PSI	-51 °F
Threaded Coupling - 2"	SA-105	B	125.00 PSI	-155 °F

Component with highest MDMT: Shell 1.

Computed MDMT = -20 °F

The required design MDMT of -20 °F has been met or exceeded for the calculated MDMT values.

ASME Flanges Are Not Included in MDMT Calculations.

Pressure Vessel Engineering, Ltd.

Vertical Vessel with Bolted Cover

Customer: **Pressure Vessel Engineering**

Job No: PVE Sample 14

Vessel Number: 2

Date Printed: 6/19/2009

MAWP Report by Components

<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP New & Cold UG-98(a)</u>	<u>Component MAWP Hot & Corroded UG-98(b)</u>	<u>Vessel MAWP Hot & Corroded UG-98(a)</u>
Shell 1	125.00 PSI	1.95 PSI	193.58 PSI	146.44 PSI	144.49 PSI
ASME Flange Class: 150 Gr:1.1		0.00 PSI	285.00 PSI	260.00 PSI	260.00 PSI
Nozzle 1	125.00 PSI	1.95 PSI	197.67 PSI	159.33 PSI	157.38 PSI
ASME Flange Class: 150 Gr:1.1		1.95 PSI	283.05 PSI	260.00 PSI	258.05 PSI
Nozzle 2	125.00 PSI	1.95 PSI	277.43 PSI	161.57 PSI	159.62 PSI
ASME Flange Class: 150 Gr:1.1		1.95 PSI	283.05 PSI	260.00 PSI	258.05 PSI
Head 1	125.00 PSI	1.95 PSI	213.93 PSI	155.69 PSI	153.74 PSI
Threaded Coupling - 1"	125.00 PSI	1.95 PSI	278.69 PSI	202.73 PSI	200.78 PSI
36" Blind Flange	125.00 PSI	0.00 PSI	387.92 PSI	387.92 PSI	387.92 PSI
Threaded Coupling - 2"	125.00 PSI	0.00 PSI	693.32 PSI	579.55 PSI	579.55 PSI

NC = Not Calculated Inc = Incomplete

Summary

Component with the lowest vessel MAWP(New & Cold) : **Shell 1**

The lowest vessel MAWP(New & Cold) : **193.58 PSI**

Component with the lowest vessel MAWP(Hot & Corroded) : **Shell 1**

The lowest vessel MAWP(Hot & Corroded) : **144.49 PSI**

Pressures are exclusive of any external loads.

Flange pressures listed here do not consider external loadings

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE Sample 14

Vessel Number: 2

Date Printed: 6/19/2009

Summary Information

	<u>Dry Weight</u>	<u>Flooded Weight</u>
Shell	328.70 lb.	1825.50 lb.
Head	113.24 lb.	396.18 lb.
Nozzle	153.47 lb.	153.47 lb.
Flange	1469.68 lb.	1469.68 lb.
ASME Flange	165.00 lb.	165.00 lb.
Totals	<hr/> 2230.09 lb.	<hr/> 4009.82 lb.
	<u>Volume</u>	
Shell	179.17 Gal.	
Head	33.93 Gal.	
Nozzle	16.53 Gal.	
Totals	<hr/> 229.62 Gal.	
	<u>Area</u>	
Shell	32.84 Sq. Ft.	
Head	11.23 Sq. Ft.	
Nozzle	10.67 Sq. Ft.	
Totals	<hr/> 54.74 Sq. Ft.	

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE Sample 14

Vessel Number: 2

Date Printed: 6/19/2009

Hydrostatic Test Information Par. UG-99(b)
Gauge at Top

Component	Const.	x	S_{Test}	/	S_{Design}	x	Pressure	=	Component Hydro Test Pressure
Head 1	1.3	x	20000	/	20000	x	125.00	=	162.50
Nozzle 1	1.3	x	17100	/	17100	x	125.00	=	162.50
Nozzle 2	1.3	x	17100	/	17100	x	125.00	=	162.50
Shell 1	1.3	x	20000	/	20000	x	125.00	=	162.50
Threaded Coupling - 1"	1.3	x	20000	/	20000	x	125.00	=	162.50

Calculated Test Pressure: 162.50 PSI

Special Notes:

This calculation assumes one chamber.

This calculation is limited by the lowest component pressure per chamber.